



Hydrant ID	Test Date	Time	Tester	Static	Resid.	Test Flow GPM	Predicted Flow @ (psi)	Predicted Flow (10 psi)	Gallons Used	NFPA Class	NFPA Color
CT-CIM01 #3773 - 2005 AD B84B - 30.637533/ 97.781769	11/18/2011		CAPITAL HYD	100	94	1,519	6,154 @20	6,558	1,519	AA	Light Blue
CT-CIM02 #3865 - 2001 AD B84B - 30.639195/ 97.783027	11/18/2011		CAPITAL HYD	100	92	1,538	5,332 @20	5,682	1,538	AA	Light Blue
CT-CIM03 #3855 - 2001 AD B84B - 30.640287/ 97.783973	11/18/2011		CAPITAL HYD	100	94	1,538	6,228 @20	6,638	1,538	AA	Light Blue
CT-CIM04 #3847 - 2001 AD B84B - 30.641428/ 97.784556	11/18/2011		CAPITAL HYD	100	94	1,482	6,002 @20	6,396	1,482	AA	Light Blue
CT-CIM05 #3827 - 2001 AD B84B - 30.643081/ 97.784971	11/18/2011		CAPITAL HYD	100	94	1,538	6,228 @20	6,638	1,538	AA	Light Blue
CT-CIM06 #3821 - 2001 AD B84B - 30.645277/ 97.785189	11/18/2011		CAPITAL HYD	102	94	1,538	5,404 @20	5,750	1,538	AA	Light Blue
CT-CIM07 #3942 - 2001 AD B84B - 30.644275/ 97.785784	11/18/2011		CAPITAL HYD	102	94	1,556	5,468 @20	5,818	1,556	AA	Light Blue
CT-CIM08 #3806 - 2001 AD B84B - 30.643370/ 97.786453	11/18/2011		CAPITAL HYD	102	94	1,538	5,404 @20	5,750	1,538	AA	Light Blue
CT-CIM09 #3792 - 2001 AD B84B - 30.642328/ 97.787545	11/18/2011		CAPITAL HYD	102	92	1,538	4,790 @20	5,098	1,538	AA	Light Blue
CT-CIM10 #3787 - 2001 AD B84B - 30.641419/ 97.786578	11/18/2011		CAPITAL HYD	112	102	1,538	5,098 @20	5,390	1,538	AA	Light Blue
CT-CIM11 #3780 - 2001 AD B84B - 30.641699/ 97.788129	11/18/2011		CAPITAL HYD	112	102	1,529	5,067 @20	5,357	1,529	AA	Light Blue
CT-CIM12 #3790 - 2001 AD B84B - 30.642041/ 97.790163	11/18/2011		CAPITAL HYD	112	102	1,538	5,098 @20	5,390	1,538	AA	Light Blue
CT-CIM13 #3901 - 2001 AD B84B - 30.641756/ 97.790967	11/18/2011		CAPITAL HYD	112	108	1,618	8,797 @20	9,301	1,618	AA	Light Blue
CT-CIM14 #3895 - 2001 AD B84B - 30.642660/ 97.791644	11/18/2011		CAPITAL HYD	112	108	1,601	8,702 @20	9,201	1,601	AA	Light Blue
CT-CIM15 #3883 - 2001 AD B84B - 30.642816/ 97.792577	11/18/2011		CAPITAL HYD	102	99	1,609	9,605 @20	10,220	1,609	AA	Light Blue
CT-CIM16 #3871 - 2001 AD B84B - 30.641656/ 97.792835	11/18/2011		CAPITAL HYD	102	98	1,565	7,996 @20	8,509	1,565	AA	Light Blue
CT-CIM17 #3868 - 2001 AD B84B - 30.640759/ 97.792831	11/18/2011		CAPITAL HYD	102	98	1,547	7,904 @20	8,410	1,547	AA	Light Blue
CT-CIM18 #3907 - 2001 AD B84B - 30.641089/ 97.791989	11/18/2011		CAPITAL HYD	102	98	1,565	7,996 @20	8,509	1,565	AA	Light Blue
CT-CIM19 #3919 - 2001 AD B84B - 30.640634/ 97.791404	11/18/2011		CAPITAL HYD	112	104	1,592	5,952 @20	6,293	1,592	AA	Light Blue
CT-CIM20 #3913 - 2001 AD B84B - 30.640561/ 97.790235	11/18/2011		CAPITAL HYD	112	102	1,609	5,335 @20	5,640	1,609	AA	Light Blue
CT-CIM21 #3928 - 2001 AD B84B - 30.640522/ 97.789653	11/18/2011		CAPITAL HYD	112	102	1,627	5,392 @20	5,701	1,627	AA	Light Blue
CT-CIM22 #3403 - 2000 AD B84B - 30.640097/ 97.793364	11/18/2011		CAPITAL HYD	94	90	1,556	7,521 @20	8,054	1,556	AA	Light Blue
CT-CIM23 #3400 - 2000 AD B84B - 30.639911/ 97.795069	11/18/2011		CAPITAL HYD	94	92	1,574	11,062 @20	11,846	1,574	AA	Light Blue

Hydrant ID	Test Date	Time	Tester	Static	Resid.	Test Flow GPM	Predicted Flow @ (psi)	Predicted Flow (10 psi)	Gallons Used	NFPA Class	NFPA Color
CT-CIM24 #3394 - 2005 Clow Medallion - 30.639499/97.796341	11/18/2011		CAPITAL HYD	88	84	1,519	7,017 @20	7,556	1,519	AA	Light Blue
CT-CIM25 #10168 - 2008 Clow Medallion - 30.639662/97.796453	11/18/2011		CAPITAL HYD	88	83	1,519	6,220 @20	6,698	1,519	AA	Light Blue
CT-CIM26 #3390 - 2000 AD B84B - 30.638437/97.796071	11/18/2011		CAPITAL HYD	88	84	1,501	6,930 @20	7,463	1,501	AA	Light Blue
CT-CIM27 #3388 - 2000 AD B84B - 30.637894/97.794910	11/18/2011		CAPITAL HYD	94	92	1,510	10,613 @20	11,365	1,510	AA	Light Blue
CT-CIM28 #3385 - 2000 AD B84B - 30.637743/97.794005	11/18/2011		CAPITAL HYD	94	92	1,519	10,679 @20	11,435	1,519	AA	Light Blue
CT-CIM29 #10188 - 2004 Kennedy K81D - 30.638084/97.793932	11/18/2011		CAPITAL HYD	94	90	1,529	7,389 @20	7,912	1,529	AA	Light Blue
CT-CIM30 #3411 - 2001 AD B84B - 30.638023/97.791219	11/18/2011		CAPITAL HYD	98	94	1,601	7,960 @20	8,496	1,601	AA	Light Blue
CT-CIM31 #3729 - 2005 AD B84B - 30.637462/97.787555	11/18/2011		CAPITAL HYD	98	94	1,609	8,004 @20	8,542	1,609	AA	Light Blue
CT-CIM32 #3740 - 2005 AD B84B - 30.637346/97.785968	11/18/2011		CAPITAL HYD	94	88	1,519	5,900 @20	6,318	1,519	AA	Light Blue
CT-CIM33 #3764 - 2005 AD B84B - 30.637405/97.784398	11/18/2011		CAPITAL HYD	94	88	1,519	5,900 @20	6,318	1,519	AA	Light Blue
CT-CIM34 #3731 - 2006 AD B84B - 30.638108/97.786409	11/18/2011		CAPITAL HYD	94	92	1,510	10,613 @20	11,365	1,510	AA	Light Blue
CT-CIM35 #3758 - 2005 AD B84B - 30.639027/97.786333	11/18/2011		CAPITAL HYD	98	92	1,501	5,996 @20	6,399	1,501	AA	Light Blue
CT-CIM36 #3750 - 2005 AD B84B - 30.639284/97.786664 - Cl: 2.2 ppm	11/18/2011		CAPITAL HYD	98	90	1,519	5,197 @20	5,547	1,519	AA	Light Blue
CT-CIM37 #3716 - 2005 AD B84B - 30.639990/97.788520	11/18/2011		CAPITAL HYD	104	100	1,609	8,330 @20	8,852	1,609	AA	Light Blue
CT-CIM38 #3711 - 2005 AD B84B - 30.639501/97.788189	11/18/2011		CAPITAL HYD	104	100	1,609	8,330 @20	8,852	1,609	AA	Light Blue
CT-CIM39 #3698 - 2005 AD B84B - 30.638388/97.789109	11/18/2011		CAPITAL HYD	104	102	1,627	12,243 @20	13,010	1,627	AA	Light Blue
CT-CIM40 #3381 - 2000 AD B84B - 30.637555/97.792808	11/18/2011		CAPITAL HYD	96	94	1,609	11,475 @20	12,267	1,609	AA	Light Blue
CT-CIM41 #3406 - 2000 AD B84B - 30.636624/97.792898	11/18/2011		CAPITAL HYD	102	100	1,644	12,213 @20	12,996	1,644	AA	Light Blue
CT-CIM42 #7544 - 2000 Mueller - 30.636375/97.791702	11/18/2011		CAPITAL HYD	102	100	1,644	12,213 @20	12,996	1,644	AA	Light Blue
CT-CIM43 #10185 - 2007 Clow Medallion - 30.634601/97.797838	11/18/2011		CAPITAL HYD	88	84	1,519	7,017 @20	7,556	1,519	AA	Light Blue
CT-CIM44 #10195 - 2001 AD B84B - 30.639027/97.794809	11/18/2011		CAPITAL HYD	100	96	1,574	7,935 @20	8,457	1,574	AA	Light Blue
CT-CIM45 #10194 - 2001 AD B84B - 30.638955/97.794457	11/18/2011		CAPITAL HYD	100	96	1,556	7,845 @20	8,360	1,556	AA	Light Blue
CT-CIM46 #40198 - 2007 Kennedy K81D - 30.639047/97.793880	11/18/2011		CAPITAL HYD	100	96	1,574	7,935 @20	8,457	1,574	AA	Light Blue
CT-CIM47 #3545 - 2004 AD B84B - 30.648501/97.793143	11/18/2011		CAPITAL HYD	112	92	1,574	3,588 @20	3,794	1,574	AA	Light Blue

Hydrant ID	Test Date	Time	Tester	Static	Resid.	Test Flow GPM	Predicted Flow @ (psi)	Predicted Flow (10 psi)	Gallons Used	NFPA Class	NFPA Color
CT-CIM48 #3553 - 2004 AD B84B - 30.649258/ 97.793576	11/18/2011		CAPITAL HYD	112	92	1,574	3,588 @20	3,794	1,574	AA	Light Blue
CT-CIM49 #3540 - 2004 AD B84B - 30.648146/ 97.792288	11/18/2011		CAPITAL HYD	110	94	1,556	3,954 @20	4,186	1,556	AA	Light Blue
CT-CIM50 #3530 - 2004 AD B84B - 30.646962/ 97.792245	11/18/2011		CAPITAL HYD	110	94	1,574	4,000 @20	4,234	1,574	AA	Light Blue
CT-CIM51 #3514 - 2004 AD B84B - 30.645862/ 97.792919	11/18/2011		CAPITAL HYD	110	92	1,583	3,775 @20	3,996	1,583	AA	Light Blue
CT-CIM52 #3522 - 2004 AD B84B - 30.644904/ 97.794192	11/18/2011		CAPITAL HYD	110	92	1,583	3,775 @20	3,996	1,583	AA	Light Blue
CT-CIM53 #3505 - 2004 AD B84B - 30.645918/ 97.794696	11/18/2011		CAPITAL HYD	110	92	1,592	3,796 @20	4,018	1,592	AA	Light Blue
CT-CIM54 #3482 - 2000 AD B84B - 30.645734/ 97.795939	11/18/2011		CAPITAL HYD	110	92	1,592	3,796 @20	4,018	1,592	AA	Light Blue
CT-CIM55 #3469 - 2000 AD B84B - 30.644744/ 97.796706	11/18/2011		CAPITAL HYD	100	88	1,556	4,334 @20	4,619	1,556	AA	Light Blue
CT-CIM56 #3485 - 2000 AD B84B - 30.644053/ 97.797911	11/18/2011		CAPITAL HYD	100	88	1,556	4,334 @20	4,619	1,556	AA	Light Blue
CT-CIM57 #3492 - 2000 AD B84B - 30.644756/ 97.798329	11/18/2011		CAPITAL HYD	100	82	1,501	3,358 @20	3,579	1,501	AA	Light Blue
CT-CIM58 #3497 - 2000 AD B84B - 30.643541/ 97.799581	11/18/2011		CAPITAL HYD	100	82	1,501	3,358 @20	3,579	1,501	AA	Light Blue
CT-CIM59 #3459 - 2000 AD B84B - 30.643723/ 97.796731	11/18/2011		CAPITAL HYD	100	90	1,519	4,670 @20	4,977	1,519	AA	Light Blue
CT-CIM60 #3439 - 2000 AD B84B - 30.642840/ 97.795636	11/18/2011		CAPITAL HYD	100	89	1,538	4,490 @20	4,785	1,538	AA	Light Blue
CT-CIM61 #3449 - 2000 AD B84B - 30.643744/ 97.794792	11/18/2011		CAPITAL HYD	100	90	1,519	4,670 @20	4,977	1,519	AA	Light Blue
CT-CIM62 #3437 - 2001 AD B84B - 30.642294/ 97.796255	11/18/2011		CAPITAL HYD	102	90	1,538	4,341 @20	4,620	1,538	AA	Light Blue
CT-CIM63 #3431 - 2000 AD B84B - 30.641704/ 97.795411	11/18/2011		CAPITAL HYD	102	90	1,529	4,315 @20	4,592	1,529	AA	Light Blue
CT-CIM64 #3419 - 2000 AD B84B - 30.640904/ 97.795701	11/18/2011		CAPITAL HYD	102	90	1,565	4,418 @20	4,701	1,565	AA	Light Blue
CT-CIM65 #3424 - 2000 AD B84B - 30.640854/ 97.795041	11/18/2011		CAPITAL HYD	102	90	1,574	4,443 @20	4,728	1,574	AA	Light Blue
CT-CIM66 #3568 - 2002 AD B84B - 30.644410/ 97.789408	11/18/2011		CAPITAL HYD	114	108	1,695	7,488 @20	7,908	1,695	AA	Light Blue
CT-CIM67 #3594 - 2002 AD B84B - 30.645401/ 97.788683	11/18/2011		CAPITAL HYD	114	108	1,686	7,451 @20	7,869	1,686	AA	Light Blue
CT-CIM68 #3581 - 2002 AD B84B - 30.646117/ 97.789418 ** Main valve leak**	11/18/2011		CAPITAL HYD	114	108	1,686	7,451 @20	7,869	1,686	AA	Light Blue
CT-CIM69 #3589 - 2002 AD B84B - 30.646943/ 97.788227	11/18/2011		CAPITAL HYD	114	108	1,695	7,488 @20	7,908	1,695	AA	Light Blue
CT-CIM70 #3604 - 2002 AD B84B - 30.648097/ 97.788121	11/18/2011		CAPITAL HYD	112	108	1,653	8,985 @20	9,499	1,653	AA	Light Blue
CT-CIM71 #3617 - 2002 AD B84B - 30.649413/ 97.788003	11/18/2011		CAPITAL HYD	112	108	1,661	9,031 @20	9,548	1,661	AA	Light Blue

Hydrant ID	Test Date	Time	Tester	Static	Resid.	Test Flow GPM	Predicted Flow @ (psi)	Predicted Flow (10 psi)	Gallons Used	NFPA Class	NFPA Color
CT-CIM72 #3625 - 2002 AD B84B - 30.650683/97.787803	11/18/2011		CAPITAL HYD	112	106	1,644	7,181 @20	7,592	1,644	AA	Light Blue
CT-CIM73 #3633 - 2002 AD B84B - 30.650978/97.789156	11/18/2011		CAPITAL HYD	112	108	1,661	9,031 @20	9,548	1,661	AA	Light Blue
CT-CIM74 #3638 - 2002 AD B84B - 30.651967/97.788355	11/18/2011		CAPITAL HYD	112	108	1,644	8,938 @20	9,450	1,644	AA	Light Blue
CT-CIM75 #3646 - 2002 AD B84B - 30.65170/97.790157	11/18/2011		CAPITAL HYD	110	90	1,501	3,381 @20	3,579	1,501	AA	Light Blue
CT-CIM76 #3653 - 2002 AD B84B - 30.652338/97.789635	11/18/2011		CAPITAL HYD	110	90	1,538	3,465 @20	3,667	1,538	AA	Light Blue
CT-CIM77 #3663 - 2002 AD B84B - 30.650424/97.790463	11/18/2011		CAPITAL HYD	110	82	1,501	2,819 @20	2,984	1,501	AA	Light Blue
CT-CIM78 #3669 - 2002 AD B84B - 30.650549/97.791581	11/18/2011		CAPITAL HYD	110	82	1,510	2,837 @20	3,003	1,510	AA	Light Blue
CT-CIM79 #3677/3678 - 2002 AD B84B - 30.649561/97.790526	11/18/2011		CAPITAL HYD	110	84	1,519	2,971 @20	3,145	1,519	AA	Light Blue
CT-CIM80 #3687 - 2002 AD B84B - 30.648299/97.790331	11/18/2011		CAPITAL HYD	110	82	1,510	2,837 @20	3,003	1,510	AA	Light Blue

From Hydrant CT-CIM01  
From Address !  
From Test Date 01/01/1901

To Hydrant CT-CIM80

**Total Gallons Used 125,324**  
**Reported on 80 flow tests**